



CERTIFICATE FI 25224 M1

Our Ref. 252227-1, 269764-1

Product XLPE-insulated power cable

Type AXMK
AXMK-PE

Trade mark NEXANS GS

**Certificate Holder/
Manufacturer** Nexans Sweden AB
SE-51481 GRIMSÅS
SWEDEN

Technical information Number and nominal cross-sectional area of conductors:
AXMK: 1 x 35-1000 mm²
4 x 16-300 mm²
AXMK-PE: 4-5 x 10-240 mm²

Other information Rated voltage 0,6/1 kV
AXMK with XLPE insulation and PVC sheath
AXMK-PE with XLPE insulation and PE sheath

The product is certified according to the following standard(s) HD 603 S1:1994 + A1:1997 + A2:2003 + A3:2007 Part 5 Section D
SFS 4879:2008

Validity This certificate is valid until 23 April 2017 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Directive information The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.

Date of issue 31 December 2012

Signature **SGS Fimko Ltd**

Sixten Lökfors
Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.