

DECLARATION OF CONFORMITY

according to
the Low Voltage Directive, 2006/95/EC, including amendments by
the CE marking Directive, 93/68/EC and
the RoHS Directive, 2011/65/EC

Type of equipment: CABLE

Type designation: EXQJ 1 kV, FXQJ 1 kV, AXQJ 1 kV, FXQJ 1kV EMC

Manufacturer: Nexans Sweden AB

Site: Grimsås

The following harmonised European standards or technical specifications have been applied:

<i>Standards</i>	<i>Test reports issued by</i>	<i>regarding</i>
SS424 14 18 / HD 603 5P in appl. parts and BS6724 (outer sheath) IEC 60502-1	Intertek-SEMKO Nexans (internal)	electrical safety electrical safety

Additional information

- The product complies in applicable parts with the technical standard listed above.
- The product is fire retardant acc to SS-EN 60332-3-24 cat C (F4C)
- The product is halogen free acc to SS-EN 50267-2-2 and low smoke acc to SS-EN 61034-2

We have an internal production control system that ensures compliance between the manufactured products and the technical documentation.

Our quality system complies with EN ISO 9001: 2008 and is certified by:

Bureau Veritas Certification Sverige AB certificate no 004193-1

The product is CE marked in 1999

As manufacturer established within the EEA, we declare under our sole responsibility that the equipment follows the provisions of the Directives stated above and is tested to the above mentioned standards.

August 17, 2015

Nexans Sweden AB
Building, Telecom and Utility
Quality

Olle Jarvid

