

DECLARATION OF CONFORMITY

No. 2015-12-15-2

Product name: Gray colored pliable conduits for electrical wire insulation with wire and without wire

Product identification element: EN 61386-22 Electro EXM-W ja EXM

Product technical regulation: EVS-EN 61386-1:2008 Conduit systems for cable management -- Part 1: General requirements.
EVS-EN 61386-22:2004 Conduit Systems for cable management - Part 22: Particular requirements - Pliable conduit systems.
EVS-EN 60423:2007 Conduit systems for cable management - Outside diameters of conduits for electrical installations and threads for conduits and fittings.

Product application area: The indoor pliable conduits for electrical wire insulation

Product classification code: 2221

Declared product properties	Classification	Unit	Value	Method
Material	-	-	PVC-U	-
Nominal outside diameter	-	mm	16, 20, 25, 32, 40, 50	EVS-EN 60423:2007
Compression force	2	N	320 (light)	EVS-EN 61386-22:2004 EVS-EN 61386-1:2008
Resistance to impact	2	-	Light: 1 kg; 100 mm	
Lower temperature range	2	°C	-5	
Upper temperature range	1	°C	+60	

Manufacturer: Pipelife Eesti AS
Põrguvälja tee 4, Lehmja, Rae vald, Harjumaa 75306, Estonia

Place of manufacturing: Pipelife Eesti AS
Põrguvälja tee 4, Lehmja, Rae vald, Harjumaa 75306, Estonia

With this declaration of conformity Pipelife Eesti AS declares that the products conform to the requirements as stated in above mentioned product technical regulations and declared product properties.

Pipelife Eesti AS holds the certificate of conformity no 5527-03 issued by Inspecta Sertifiointi Oy assuring that the quality management system of Pipelife Eesti AS conforms to the requirements of the standard ISO 9001:2008.

Issue date: 15th of December 2015

Signed by: 

Lembit Salla

Pipelife Eesti AS Technical and Quality Manager