



ISO 9001

Põrguvälja tee 4
EE 75306 Tallinn Estonia
Tel. +372 605 5100
Fax +372 605 5101
E-mail: pipelife@pipelife.ee

DECLARATION OF CONFORMITY

No. 2012-06-14-1

Product description:	Corrugated double wall cable conduits in coils for buried underground applications
Nominal dimensions:	Ø 50 mm, Ø 75 mm, Ø 110 mm, Ø 160 mm
Resistance to compression:	450 N
Resistance to impact:	L
Resistance to bending:	Pliable
Material:	
Corrugated outer layer:	HDPE
Inner layer:	LDPE
Product standard:	EVS-EN 61386-24:2010 Conduit systems for cable management - Part 24: Particular requirements. Conduit systems buried underground EVS-EN 61386-1:2008 Conduit systems for cable management -- Part 1: General requirements
Manufacturer:	Pipelife Eesti AS
Place of manufacturing:	Põrguvälja tee 4, Lehmja, Rae vald, Estonia

Hereby Pipelife Eesti AS confirms that products mentioned above are manufactured in accordance to the requirements of the standards mentioned above. Pipelife Eesti AS holds the certificate of conformity no 5527-02 issued by Inspecta Sertifiointi Oy assuring that the quality management system of Pipelife Eesti AS conforms to the requirements of the standard ISO 9001:2008.

Issue date: 14.06.2012



Lembit Salla
Quality and Technical Manager